

Sarah Stokowski  
Mayor

Steven Miller  
Administrator

Amber Barnes  
Assistant Administrator



COUNCIL

Lyn Merchant  
Ward 1

Barbara Hamberg  
Ward 2

Nancy von Meyer  
Ward 3

Jeffrey Van Drie  
Ward 4

**Public Notice**  
Sewer Overflow Notification

A sewer overflow occurred at **Town Creek Pump Station off East Queen Street** on **January 26, 2026** from **4:00PM-7:00PM**.

As a provider of sanitary sewers for the Town of Pendleton, the Water/Sewer Department has an obligation to notify our customers when an overflow event happens in the area.

The overflow was approximately **2,000 GALLONS** due to a **power outage** at the pump station. A Water/Sewer crew was dispatched to address and stop the overflow as quickly as possible. The spillage was neutralized using hydrated lime. To the best of our knowledge, the overflow **DID NOT** reach a body of water. We recommend staying clear of the vicinity for the next week to allow the area to return to its natural state.

At this time, there is no further action required from the public. If additional information or precautions become necessary, updates will be provided.

We apologize for any inconvenience this may have caused.

If you have any questions, you may contact Terry Reed, Assistant Public Works Director at 864-646-9073.